



Report of Analysis

Name: CICWCD
88 E Fiddlers Canyon Rd #220
Cedar City, UT 84721
Sample Date: 9/12/2024 7:15:00 AM
Receipt Date: 9/12/2024 4:40:00 PM
Report Date: 10/30/2024
Sample Site: ~~XXXX~~ W 1925 S

Sample ID#: K2024 02248
Sample Type: Drinking Water
Sampler: TYLER GLOVER

| Parameter | Sample Result | Units | MRL | Method | Analysis Date | Analysis Time | Analyst |
|-----------------------|---------------|-------|-----|--------|---------------|---------------|---------|
| Receiving pH | 7.59 | SU | 0 | 4500 H | 9/12/2024 | 6:00:00 PM | MF |
| Receiving Temperature | 24.9 | C | 0 | 2550 | 9/12/2024 | 6:00:00 PM | MF |
| Copper | 11.0 | ug/L | 1 | 200.8 | 10/14/2024 | 10:09:00 AM | BR |
| Lead | <1 | ug/L | 1 | 200.8 | 10/14/2024 | 10:09:00 AM | BR |

Report Approved By: 
Kim Weaver, Director




Report of Analysis

Name: CICWCD
 88 E Fiddlers Canyon Rd #220
 Cedar City, UT 84721
Sample Date: 9/12/2024 9:00:00 AM
Receipt Date: 9/12/2024 4:40:00 PM
Report Date: 10/30/2024
Sample Site: ~~XXXX~~ S Chekshani Cliffs

Sample ID#: K2024 02249
Sample Type: Drinking Water
Sampler: TYLER GLOVER

| Parameter | Sample Result | Units | MRL | Method | Analysis Date | Analysis Time | Analyst |
|-----------------------|---------------|-------|-----|--------|---------------|---------------|---------|
| Receiving pH | 7.94 | SU | 0 | 4500 H | 9/12/2024 | 6:00:00 PM | MF |
| Receiving Temperature | 24.6 | C | 0 | 2550 | 9/12/2024 | 6:00:00 PM | MF |
| Copper | 74.2 | ug/L | 1 | 200.8 | 10/14/2024 | 10:09:00 AM | BR |
| Lead | <1 | ug/L | 1 | 200.8 | 10/14/2024 | 10:09:00 AM | BR |

Report Approved By: 
 Kim Weaver, Director



Report of Analysis

Name: CICWCD
 88 E Fiddlers Canyon Rd #220
 Cedar City, UT 84721
Sample Date: 9/12/2024 9:00:00 AM
Receipt Date: 9/12/2024 4:40:00 PM
Report Date: 10/30/2024
Sample Site: ~~XXXX~~ Chekshani Cliffs

Sample ID#: K2024 02250
Sample Type: Drinking Water
Sampler: TYLER GLOVER

| Parameter | Sample Result | Units | MRL | Method | Analysis Date | Analysis Time | Analyst |
|-----------------------|---------------|-------|-----|--------|---------------|---------------|---------|
| Receiving pH | 7.67 | SU | 0 | 4500 H | 9/12/2024 | 6:00:00 PM | MF |
| Receiving Temperature | 24.9 | C | 0 | 2550 | 9/12/2024 | 6:00:00 PM | MF |
| Copper | 80.3 | ug/L | 1 | 200.8 | 10/14/2024 | 10:09:00 AM | BR |
| Lead | 28.2 | ug/L | 1 | 200.8 | 10/14/2024 | 10:09:00 AM | BR |

Report Approved By: 
 Kim Weaver, Director



Report of Analysis

Name: CICWCD
88 E Fiddlers Canyon Rd #220
Cedar City, UT 84721
Sample Date: 9/12/2024 7:30:00 AM
Receipt Date: 9/12/2024 4:40:00 PM
Report Date: 10/30/2024
Sample Site: ~~XXXX~~ Tv-ee trail

Sample ID#: K2024 02251
Sample Type: Drinking Water
Sampler: TYLER GLOVER

| Parameter | Sample Result | Units | MRL | Method | Analysis Date | Analysis Time | Analyst |
|-----------------------|---------------|-------|-----|--------|---------------|---------------|---------|
| Receiving pH | 7.81 | SU | 0 | 4500 H | 9/12/2024 | 6:00:00 PM | MF |
| Receiving Temperature | 24.9 | C | 0 | 2550 | 9/12/2024 | 6:00:00 PM | MF |
| Copper | 161 | ug/L | 1 | 200.8 | 10/14/2024 | 10:09:00 AM | BR |
| Lead | <1 | ug/L | 1 | 200.8 | 10/14/2024 | 10:09:00 AM | BR |

Report Approved By: 
Kim Weaver, Director



Report of Analysis

Name: CICWCD
 88 E Fiddlers Canyon Rd #220
 Cedar City, UT 84721
Sample Date: 9/12/2024 6:15:00 AM
Receipt Date: 9/12/2024 4:40:00 PM
Report Date: 10/30/2024
Sample Site: ~~XXXX~~ Chuwi path

Sample ID#: K2024 02252
Sample Type: Drinking Water
Sampler: TYLER GLOVER

| Parameter | Sample Result | Units | MRL | Method | Analysis Date | Analysis Time | Analyst |
|-----------------------|---------------|-------|-----|--------|---------------|---------------|---------|
| Receiving pH | 7.88 | SU | 0 | 4500 H | 9/12/2024 | 6:00:00 PM | MF |
| Receiving Temperature | 24.1 | C | 0 | 2550 | 9/12/2024 | 6:00:00 PM | MF |
| Copper | 38.5 | ug/L | 1 | 200.8 | 10/14/2024 | 10:09:00 AM | BR |
| Lead | 2.51 | ug/L | 1 | 200.8 | 10/14/2024 | 10:09:00 AM | BR |

Report Approved By: 
 Kim Weaver, Director

